

2010 Consumer Confidence Report

Water System Name: Stallion Springs CSD Report Date: June 8th 2010

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2009.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Seven groundwater wells

Name & location of source(s): CV Well #1, CV Well #2, Leisure Well, Y-23 Well, P-17 Well, Bold Venture Well, Buckpasser Well (Two wells are located in the Cummings Valley Five wells are located within the Stallion Springs. *Bold Venture, Buckpasser & P-17 wells were not utilized in the calendar year 2010. No sample information was listed*

Drinking Water Source Assessment information: Drinking Water Source Assessment water completed in 2001.
A copy of this report is available for review at the CSD office.

Time and place of regularly scheduled board meetings for public participation: Third Tuesday of every month.
7:00 PM @ 27800 Stallion Springs Dr.

For more information, contact: Tyler Napier Phone: (661)822-3268

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variations and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (ug/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the state Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	(In a mo.)	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i>	(In the year)	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in the last sample set)	No. of samples collected	90 th percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	20	0.0028	0	15	2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	20	0.37	0	1.3	0.17	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	5/28/09 & 2-19-09	43.6	26-57	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	5/28/09 & 2-19-09	139.8	9.5-240	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

*Any violation of an MC or AL is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent	Sample	Level	Range of	MCL	PHG	Typical Source of Contaminant
-------------------------	--------	-------	----------	-----	-----	-------------------------------

(and reporting units)	Date	Detected	Detections	[MRDL]	(MCLG) [MRDLG]	
Gross Alpha (ug/L)	5/25/10-6/7/2010	1.65	ND-4.64	15	(0)	Erosion of Natural Deposits
Uranium (ug/L)	2002-2004	12.3	2.07-18.7	15	0.43	Erosion of Natural Deposits
Radium 228	5/28/09 & 2-19-09	2007	1.0-1.76	5	(0)	Erosion of Natural Deposits
Barium (ppm)	5/28/09 & 2-19-09	0.030	ND-0.12	1	2	Erosion of Natural Deposits
Chlorine (ppm)	Daily	0.5	ND-1.8	4.0	4.0	Added as a disinfectant
Chromium (ppb)	5/28/09 & 2-19-09	ND	ND	50	(100)	Erosion of Natural Deposits
Fluoride (ppm)	5/28/09 & 2-19-09	0.31	0.19-0.70	2	1	Erosion of Natural Deposits
Nitrate (ppm)	3/31/10-11-9-10	21.1	ND-29.0	45	45	Erosion of Natural Deposits, leaching from fertilizer use and septic systems
Selenium (ppb)	5/28/09 & 2-19-09	0.7	ND-2.8	50	50	Erosion of Natural Deposits
Perchlorate (ppb)	5/17/10-10/5/10	3.0	ND-4.7	6.0	6.0	Production of solid rocket propulsion and fireworks, found in groundwater due to environmental contamination.

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Chloride (ppm)	5/28/09 & 2-19-09	18.25	22-26	500	N/A	Run off from natural deposits
Color (units)	5/28/09 & 2-19-09	ND	ND	15	N/A	Naturally occurring from organic material
Iron (ppb)	5/28/09 & 2-19-09	ND	ND	500	N/A	Leaching from natural deposits
Manganese (ppb)	5/28/09 & 2-19-09	ND	ND	300	N/A	Leaching from natural deposits
Odor (units)	5/28/09 & 2-19-09	ND	ND	3	N/A	Runoff/Leaching from natural deposits
Sulfate (ppm)	5/28/09 & 2-19-09	18.25	20-31	500	N/A	Runoff/Leaching from natural deposits
TDS (ppm)	5/28/09 & 2-19-09	202	170-330	1000	N/A	Runoff/Leaching from natural deposits
Turbidity (NTU Units)	5/28/09 & 2-19-09	0.17	0.19-0.28	5	N/A	Soil runoff

*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

For Systems Providing Ground Water as a Source of Drinking Water

(Refer to page 1, "Type of water source in use" to see if your source of water is surface water or groundwater)

TABLE 7 – SAMPLING RESULTS SHOWING FECAL INDICATOR-POSITIVE GROUND WATER SOURCE SAMPLES					
Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	(In the year)	0	0	(0)	Human and animal fecal waste
Enterococci	(In the year)	0	TT	n/a	Human and animal fecal waste
Coliphage	(In the year)	0	TT	n/a	Human and animal fecal waste